

## Advisor Report - EPC Pipe

Policy Holder:	DAJEE MS	Claim No:	
Risk Address:	35A SOMERSET STREET, MAYFAIR	FOGI Order No:	973616
Policy No:	6526732181	Claim Date:	10/Jan/2014

### Claim Outcome:

Claim Outcome:	Plumbing Repairs not Covered
No Claim Reason:	Not Covered by Policy

### RISK Information:

<b>1. None</b>
----------------

### Claim Detail:

Type of Repair:	
Type of pipe or joint failed:	
What was repaired:	
Size of pipe or joint replaced:	
Was the failure on a hot water pipe:	No
Where:	in shower
Was Leak Detection done:	Yes

### General Information:

1. The building is utilised for Residential purposes
2. Please note that according to the Plumber damages occurred when the Item Failed.
3. Leak detection confirms no leaking supplies. Found shower head parts leaking, toilet cistern inners faulty, toilet braided flexi connector leaking